

Building Inspection Department

100 North Court Street Georgetown, KY 40324

Georgetown, Kr 40324			
Phone: (502) 863-9802 Fax: (502)	863-4169	☐ City	

Permit Application Form		
Permit Number		
<u>refinit (uniber</u>		
☐ City ☐ County		

The 2007 Kentucky Residential Code (KRC) shall control the de the lot of a one- or two-family dwelling.	esign and constructio	on of in-ground swimming pools install on		
Public swimming pools shall be designed and constructed according to the 2007 Kentucky Building Code (KBC). SWIMMING POOL Permit Application				
Subdivision Name:	Lot #	Lot Size		
Applicants Name	Contact Name	Contact Name		
Address	Contact Phone Numbers:			
Applicant is:	th COST of			
Pool usage:		Construction: \$		
Name of individual or company performing electric work for the	e pool			
REQUIRED DOCUMENTAT	TION FOR POOL PE	ERMITS		
 4. Proof of Kentucky Workers Compensation insurance, (if pool is installed by someone other than owner) 5. Cross section of pool showing water depths, floor and wall slopes, dimension and height of diving board above water line (if applicable). 6. Detailed plans of the pool circulation system demonstrating compliance with 2007 KRC Section AG106: Entrapment Protection for Swimming and Spa Suction Outlets. 7. Complete details of pool enclosure. Drawing must include type of fencing, height and details of openings. 				
The undersigned hereby certifies that all information is true and accurate to the best of their knowledge.				
Signature Date://				
The Permit Fee for Private Pools is \$100. Public pool fees are based on the Cost / Fee schedule.				
Remarks OFFICE U	SE ONLY			



Building Inspection Department

100 North Court Street Georgetown, KY 40324



www.georgetownky.gov

Phone: (502) 863-9802 Fax: (502) 863-4169

Swimming Pool Enclosure Requirements

Outdoor in-ground swimming pool shall be surrounded by a barrier which shall comply with the following:

- 1. The top of the barrier shall be at least 48 inches above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 4 inches measured on the side of the barrier which faces away from the swimming pool.
- 2. Openings in the barrier shall not allow passage of a 4 inch diameter sphere.
- 3. Solid Barriers which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.
- 4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 24 inches, the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1 ¾ inches in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1 ¾ inches in width.

Exception: When intermediate horizontal members are located 34 inches or more above grade, the spacing between vertical member shall not exceed 4 inches in width.

- 5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 24 inches or more, spacing between vertical members shall not exceed 4 inches. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1 ³/₄ inches in width.
- 6. Maximum mesh size for chain link fences shall be a 2 ½ square unless the fence is provided with slats fastened at the top or the bottom which reduce the openings to not less than 1 ¾ inches.
- 7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1 ³/₄ inches.
- 8. Access gates shall comply with requirements of Section AG105.2, Items 1 through 7, and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 48 inches from the bottom of the gate, the release mechanism and openings shall comply with the following:
 - 8-1. The release mechanism shall be located on the pool side of the gate at least 3 inches below the top of the gate: and
 - 8-2. The gate and barrier shall have no opening larger than ½ inch within 18 inches of the release mechanism.

Property Owners Signature Date

I acknowledge reading the above requirements and understand that I must comply.

Return signed form with the permit application to Building Inspection.

Address:



Building Inspection Department

100 North Court Street Georgetown, KY 40324 Phone: (502) 863-9802 Fax: (502) 863-4169



www.georgetownky.gov

AFFIDAVIT OF ASSURANCES* PURSUANT TO KRS 198B.060 (10)

the above referenced	that all contractors and subcontracto project shall be in compliance with	, and states, pursuant to rs employed or that will be employed on any activity under the Commonwealth of Kentucky requirements for Worker's and Unemployment Insurance (according to KRS Chapter
THIS	theday of	, 20
		Contractor, Owner or Owner's Agent
SUBSCRIBED AND S	SWORN to before me by	
Applicant, on this the	day of	, 20
My commission Expir	es:	Notary Public State At Large
	The Affidavit of Assurances is not ented the assurances upon issuance	required if the local building code official was of the local building permit.
	ections – I am aware of the requiredule those inspections.	ed inspections and the applicant's responsibility to
	-	Signature of Applicant